

# POLICIES AND PROCEDURES MANUAL

KEYSTONE COMMUNITY RESOURCES, INC.

KEYSTONE INDEPENDENT LIVING, INC.

**Policy Title:**

Physical site- Water

**Chapter:**

10

**Effective Date:**

10/25/1999

**Revision Date:****Policy Number:**

10-113-008

Executive Director

## SCOPE:

- Chapter 3800 – Child Residential and Day Treatment Facilities

## INTRODUCTION:

1. Each Keystone facility shall have hot and cold water under pressure.
2. Hot water temperature in areas accessible to children may not exceed 120(F.)
3. A Keystone facility that is not connected to a public water system shall have a coliform water test at least every 3 months, by Department of Environmental Protection-Certified laboratory, stating that the water is safe for drinking. Documentation of the certificate shall be kept.

## DISCUSSION: